

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Westridge Subdivision

PWS ID# 41 05998

Month/Year Feb / 2025

Entry Point: EP-A (EP for well)

Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0600		0.78	Emailed on 03/01/25
2	0615		0.60	
3	0615		0.63	
4	0630		0.86	
5	0715		0.74	
6	0715		0.68	
7	0615		0.77	
8	0600		0.82	
9	0700		0.87	
10	0700		1.01	
11	0600		0.86	
12	0600		0.58	
13	0700		0.71	
14	0615		0.66	
15	0615		0.81	
16	0800		0.59	
17	0615		0.54	
18	0645		0.74	
19	0600		0.57	
20	0615		0.76	
21	0615		0.83	
22	0730		0.68	
23	0615		0.69	
24	0600		0.71	
25	0800		0.61	
26	0900		0.93	
27	0615		1.13	
28	0600		1.02	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: WILLIAM W. FRANSEN

Title: SWSO

Operator Certification #:

Signature: 

Phone #: (360) 951-2683

OR

Date: 03 / 01 / 2025

Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019