

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

| | | | | |
|--------------------------------------|--|------------------------------------|---------------------------------------|--|
| System Name Westridge Subdivision | | | PWS ID# 4 1 05998 | |
| Month/Year May / 2025 | | Entry Point: EP-A (EP for well) | Required Minimum Residual 0.4 mg/L | |

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|------|------------------|--|---------------------|
| 1 | 0600 | | 0.66 | Emailed on 05/18/25 |
| 2 | 0615 | | 0.70 | |
| 3 | 0614 | | 0.78 | |
| 4 | 0630 | | 0.64 | |
| 5 | 0600 | | 0.90 | |
| 6 | 0600 | | 0.56 | |
| 7 | 0600 | | 0.88 | |
| 8 | 0630 | | 0.91 | |
| 9 | 0600 | | 0.83 | |
| 10 | 0600 | | 0.78 | |
| 11 | 0700 | | 0.60 | |
| 12 | 0600 | | 1.11 | |
| 13 | 0700 | | 0.98 | |
| 14 | 0530 | | 0.89 | |
| 15 | 0645 | | 0.97 | |
| 16 | 0630 | | 0.67 | |
| 17 | 0600 | | 0.49 | |
| 18 | 0600 | | 0.59 | |
| 19 | 0600 | | 0.55 | |
| 20 | 0900 | | 0.68 | |
| 21 | 0600 | | 0.65 | |
| 22 | 0715 | | 0.87 | |
| 23 | 0645 | | 0.87 | |
| 24 | 0645 | | 0.90 | |
| 25 | 0730 | | 0.92 | |
| 26 | 0730 | | 0.83 | |
| 27 | 0800 | | 0.73 | |
| 28 | 0600 | | 0.67 | |
| 29 | 0600 | | 0.83 | |
| 30 | 0600 | | 0.93 | |
| 31 | 0600 | | 0.74 | |

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? hours – 4 hours

Drinking Water Program to be notified by end of next business day.

| | |
|---|---|
| <p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p> | <p>GWS Serving More Than 3,300</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 65%;"> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p> </div> <div style="width: 30%;"> <p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p> </div> </div> |
|---|---|

Return by 10th of following month by either email dlwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019