

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **McKenzie Ridge Subdivision**

PWS ID# **4 1 06095**

Month/Year **Sept / 2021** Entry Point: **WTP-A**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0800	Well #1	0.6	
2	0800	Well #1	0.6	
3	0800	Well #1	0.6	
4	0800	Well #1	0.6	
5	0800	Well #1	0.6	
6	0800	Well #1	0.6	
7	0800	Well #1	0.6	
8	0800	Well #1	0.6	
9	0800	Well #1	0.6	
10	0800	Well #1	0.4	
11	0800	Well #1	0.4	
12	0800	Well #1	0.4	
13	0800	Well #1	0.6	
14	0800	Well #1	0.6	
15	0800	Well #1	0.6	
16	0800	Well #1	0.6	
17	0800	Well #1	0.6	
18	0800	Well #1	0.6	
19	0800	Well #1	0.6	
20	0800	Well #1	0.6	
21	0800	Well #1	0.6	
22	0800	Well #1	0.4	
23	0800	Well #1	0.4	
24	0800	Well #1	0.4	
25	0800	Well #1	0.4	
26	0800	Well #1	0.4	
27	0800	Well #1	0.4	
28	0800	Well #1	0.4	
29	0800	Well #1	0.4	
30	0800	Well #1	0.4	


Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No
Attach those results and submit them with this form.

GWS Serving More Than 3,300
Did continuous monitoring equipment fail at any time this reporting month? Yes No
If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____
Date it was returned to service: _____ / _____ / _____

Printed Name: **Garren Friedemann**
Signature: 
Date: **10 / 06 / 2021**

Title: **Operations Manager**
Phone #: **(541) 505-9968**

Operator Certification #: _____
OR
Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.