

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name McKenzie Ridge Subdivision

PWS ID# 4 1 06095

Month/Year May 2022

Entry Point: WTP-A

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0800	Well #1	0.4	
2	0800	Well #1	0.4	Inspection/Data collection
3	0800	Well #1	0.4	
4	0800	Well #1	0.4	
5	0800	Well #1	0.4	
6	0800	Well #1	0.4	
7	0800	Well #1	0.4	
8	0800	Well #1	0.4	
9	0800	Well #1	0.4	
10	0800	Well #1	0.4	Inspection/Data collection
11	0800	Well #1	0.4	
12	0800	Well #1	0.4	
13	0800	Well #1	0.4	
14	0800	Well #1	0.4	
15	0800	Well #1	0.4	
16	0800	Well #1	0.4	
17	0800	Well #1	0.4	Inspection/Data collection/MTR read
18	0800	Well #1	0.4	
19	0800	Well #1	0.4	
20	0800	Well #1	0.4	
21	0800	Well #1	0.4	
22	0800	Well #1	0.4	
23	0800	Well #1	0.4	Inspection/Data collection
24	0800	Well #1	0.4	
25	0800	Well #1	0.4	
26	0800	Well #1	0.4	
27	0800	Well #1	0.4	
28	0800	Well #1	0.4	
29	0800	Well #1	0.4	
30	0800	Well #1	0.4	
31	0800	Well #1	0.4	Inspection/Data collection

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Garren Friedemann

Title: Operations Manager

Operator Certification #:

Signature: 

Phone #: (541) 505-9968

OR

Date: 06 / 01 / 2021

Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dpw.dmce@state.or.us](mailto:dpw.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019