## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095						
Month/Year June 2022 Entry Point: WTP-A Required Minimum Residual 0.20 mg/L						
Date	Time	Source(s) ir	i use	Lowest free chlorine residual at entry point to distribution system (mg/L)	residual at entry point to Notes	
1	0800	Well #1		0.40		
2	0800	Well #1		0.40		
3	0800	Well #1		0.40		
4	0800	Well #1		0.40		
5	0800	Well #1		0.40		
6	0800	Well #1		0.40		
7	0800	Well #1		0.40	Inspection/Data collection	
8	0800	Well #1		0.40		
9	0800	Well #1		0.40		
10	0800	Well #1		0.40		
11	0800	Well #1		0.40		
12	0800	Well #1		0.40		
13	0800	Well #1		0.40	Inspection/Data collection	
14	0800	Well #1		0.40		
15	0800	Well #1		0.40		
16	0800	Well #1		0.40		
17	0800	Well #1		0.40	Inspection/Data collection/MTR read	
18	0800	Well #1		0.40		
19	0800	Well #1		0.40		
20	0800	Well #1		0.40		
21	0800	Well #1		0.40	Inspection/E	Data collection
22	0800	Well #1		0.40		
23	0800	Well #1		0.40		
24	0800	Well #1		0.40		
25	0800	Well #1		0.40		
26	0800	Well #1		0.40		
27	0800	Well #1		0.40		
28	0800	Well #1		0.40	Inspection/E	Data collection
29	0800	Well #1		0.40		
30	0800	Well #	1	0.40		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No    If yes, what was the longest time period until the required level was restored?  hours – <u>If &gt; 4 hours, Drinking Water Program to be</u> notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at any time this reporting month? Yes No		ny time this	Date continuous monitoring equipment failed:
as requ <i>Attach</i> <i>this for</i>	those results	Yes No	If yes, were grab samples collected every four hours continuous monitoring equipment was returned to se required?			Date it was returned to service:
			Attach grab sample results and submit them with the		with this form.	/ /
Printed N	Name: Garrer	n Friedemann	Title: Operations Manager		Operator Certification #:	
Signatur	e:		Phone #: (541) 505-9968		OR	
Date: 7	/ 10 / 2022				Small G	roundwater System 🖂

Return by 10<sup>th</sup> of following month by either email <u>dwp.dmce@state.or.us;</u> fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.