State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095						
Month/Year 9/2022 Entry Point: WTP-A Required Minimum Residual 0.20 mg/L						
Date	Time	Source(s) ii	ı use	Lowest free chlorine residual at entry point to distribution system (mg/L)		
1	0800	Well #	1	0.40	Inspection/Data collection	
2	0800	Well #1		0.40		
3	0800	Well #	1	0.40		
4	0800	Well #1		0.40		
5	0800	Well #1		0.40		
6	0800	Well #1		0.20	Inspection/Data collection	
7	0800	Well #1		0.60		
8	0800	Well #1		0.60		
9	0800	Well #1		0.60		
10	0800	Well #1		0.60		
11	0800	Well #1		0.60		
12	0800	Well #1		0.40		
13	0800	Well #1		0.40	Inspection/[Data collection/MTR read
14	0800	Well #1		0.40		
15	0800	Well #1		0.40		
16	0800	Well #1		0.40		
17	0800	Well #1		0.60		
18	0800	Well #1		0.60		
19	0800	Well #1		0.60		
20	0800	Well #1		0.60	Inspection/[Data collection
21	0800	Well #1		0.60		
22	0800	Well #1		0.60		
23	0800	Well #1		0.40		
24	0800	Well #1		0.40		
25	0800	Well #1		0.40		
26	0800	Well #1		0.40		
27	0800	Well #1		0.40	Inspection/[Data collection
28	0800	Well #1		0.40		
29	0800	Well #		0.40		
30	0800	Well #		0.20		
				V.=V		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving More Than 3,300						
	_					
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			reporting mont	h? Yes No	•	Date continuous monitoring equipment failed:
			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No Attach grab sample results and submit them with this form.			Date it was returned to
						service:
Printed I	Name: Garre	n Friedemann	Title: Operations Manager		Operator Certification #:	
Signatur	.0.		·		·	
_			Phone #: (541) 505-9968		OR	
Date: 10	0/3/2022				Small G	roundwater System 🔀