State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095						
Month/Year Oct. 2022 Entry Point: WTP-A Required Minimum Residual 0.20 mg/L						
Date	Time Source(s) ii		ıuse	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	0800	Well #		0.40		
2	0800	Well #1		0.40		
3	0800	Well #1		0.40		
4	0800	Well #1		0.40		
5	0800	Well #1		0.40	Inspection/[Data collection/Sample
6	0800	Well #1		0.40		
7	0800	Well #1		0.40		
8	0800	Well #1		0.40		
9	0800	Well #1		0.40		
10	0800	Well #1		0.40		
11	0800	Well #1		0.40	Inspection/Data collection	
12	0800	Well #1		0.40		
13	0800	Well #1		0.40		
14	0800	Well #1		0.40		
15	0800	Well #1		0.40	Inspection/[Data collection
16	0800	Well #1		0.40		
17	0800	Well #1		0.40		
18	0800	Well #1		0.60		
19	0800	Well #1		0.60	Inspection/[Data collection/MTR read
20	0800	Well #1		0.60		
21	0800	Well #1		0.60		
22	0800	Well #1		0.60		
23	0800	Well #1		0.60		
24	0800	Well #1		0.60		
25	0800	Well #1		0.60	Inspection/[Data collection
26	0800	Well #1		0.60		
27	0800	Well #1		0.60		
28	0800	Well #1		0.60		
29	0800	Well #	<u> </u>	0.60		
30	0800	Well #		0.40		
31	0800	Well #		0.40		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours – <u>If > 4 hours, Drinking Water Program to be notified by end of next business day.</u>						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month? No Date continuous monitoring equipment failed: If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as			I .
						required?
			Attach grab sample results and submit them with this form.			1 1
			Printed N	Name: Garre	n Friedemann	Title: Operations Manager
Signatur	æ.				OR	
			1 110116 #. (341) 303-9900			
Date: 11 / 3 / 2022 Small Groundwater System ⊠						oundwaler System 🔀