

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **McKenzie Ridge Subdivision**

PWS ID# **4 1 06095**

Month/Year **03/2023**

Entry Point: **WTP-A**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0800	Well #1	0.40	
2	0800	Well #1	0.40	
3	0800	Well #1	0.40	
4	0800	Well #1	0.40	
5	0800	Well #1	0.40	
6	0800	Well #1	0.60	
7	0800	Well #1	0.60	Inspection/Data collection
8	0800	Well #1	0.60	
9	0800	Well #1	0.60	
10	0800	Well #1	0.60	
11	0800	Well #1	0.60	
12	0800	Well #1	0.60	
13	0800	Well #1	0.60	Inspection/Data collection
14	0800	Well #1	0.60	
15	0800	Well #1	0.60	
16	0800	Well #1	0.60	
17	0800	Well #1	0.60	
18	0800	Well #1	0.60	
19	0800	Well #1	0.40	
20	0800	Well #1	0.40	
21	0800	Well #1	0.40	Inspection/Data collection/MTR read
22	0800	Well #1	0.40	
23	0800	Well #1	0.40	
24	0800	Well #1	0.40	
25	0800	Well #1	0.40	
26	0800	Well #1	0.20	
27	0800	Well #1	0.20	
28	0800	Well #1	0.20	Inspection/Data collection
29	0800	Well #1	0.20	
30	0800	Well #1	0.20	
31	0800	Well #1	0.20	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Garren Friedemann

Title: Operations Manager

Operator Certification #: 609860

Signature: _____

Phone #: (541) 505-9968

OR

Date: 4 / 01 / 2023

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.