State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	n Name	McKenzie Ridge Sub	division PWS ID# 4 1 06095									
Month/	Year July	y/2023 Entry Po	nt: WTP-A	Req	Required Minimum Residual 0.20 mg/L							
Date	Time	Source(s) in	ı use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes						
1	1 0800 Well #			0.40								
2	0800	Well #		0.40								
3	0800	Well #		0.40	Inspection/[Data collection						
4	0800	Well #		0.40								
5	0800	Well #		0.40	Inspection/Data collection							
6	0800	Well #		0.40								
7	0800	Well #1		0.40								
8	0800	Well #1		0.40								
9	0800	Well #1		0.40								
10	0800	Well #1		0.40								
11	0800	Well #1		0.40								
12	0800	Well #1		0.20								
13	0800	Well #1		0.40	Inspection/Data collection							
14	0800	Well #1		0.40	•							
15	0800	Well #1		0.40								
16	0800	Well #1		0.40								
17	0800	Well #1		0.40								
18	0800	Well #		0.60								
19	0800	Well #		0.40								
20	0800	Well #1		0.40	Inspection/Data collection/MTR read							
21	0800	Well #1		0.40	Inspection/Data collection							
22	0800	Well #1		0.40	•							
23	0800	Well #		0.60								
24	0800	Well #1		0.60								
25	0800	Well #1		0.80	Inspection/[Data collection						
26	0800	Well #1		1.00								
27	0800	Well #		1.00								
28	0800	Well #		1.00								
29	0800	Well #		1.00								
30	0800	Well #		0.80								
31	0800	Well #		0.80								
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No												
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.												
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300												
	_	·	Did continuous monitoring equipment fail at any time this Date continuous monitoring									
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			reporting month? Yes No equipment failed: If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No Attach grab sample results and submit them with this form.									
						Attach yian sample results and submit them with this form.						
						Printed I	Name: Garre	en Friedemann	Title: Operations Manager		Operator Certification #: 609860	
						Signatur	re:		Phone #: (541) 505-9968		OR	
Date: 8	/ 1 / 2023				Small G	roundwater System						