State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095						
Month/Year 09/2023 Entry Point: WTP-A Required Minimum Residual 0.20						Residual 0.20 mg/L
Date	Time	Source(s) ir	ı use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	0800 Well #		1	0.80		
2	0800	Well #1		0.80		
3	0800	Well #1		0.80		
4	0800	Well #		0.60		
5	0800	Well #1		0.80	Inspection/[Data collection
6	0800	Well #1		0.80		
7	0800	Well #1		0.80		
8	0800	Well #1		0.80		
9	0800	Well #1		0.80		
10	0800	Well #1		0.80		
11	0800	Well #1		0.80		
12	0800	Well #1		0.80	Inspection/Data collection	
13	0800	Well #1		0.80		
14	0800	Well #1		0.80		
15	0800	Well #1		0.80		
16	0800	Well #1		0.80		
17	0800	Well #1		0.80		
18	0800	Well #1		0.80		
19	0800	Well #1		0.60		
20	0800	Well #1		0.60	Inspection/[Data collection/MTR read
21	0800	Well #1		0.60		
22	0800	Well #1		0.60		
23	0800	Well #1		0.60		
24	0800	Well #1		0.40		
25	0800	Well #1		0.40		
26	0800	Well #1		0.40	Inspection/[Data collection
27	0800	Well #1		0.40		
28	0800	Well #1		0.40		
29	0800	Well #		0.40		
30	0800	Well #		0.40		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at any time this reporting month? Yes No			Date continuous monitoring
						equipment failed:
as required? Yes No			If yes, were grab samples collected every four hours until the			
Attach those results and submit them with			continuous monitoring equipment was returned to service as Date it was returned to			
this form.			required? Yes No Attach grab sample results and submit them with this t			service:
					vith this form.	1 1
Printed N	Name: Garre	n Friedemann	Title: Operations Manager		Operator Certification #: 609860	
Signatur	e:		Phone #: (541) 505-9968		OR	
	0 / 02 / 2023				Small G	roundwater System