State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095							
Month/Year 10 / 2023 Entry Point: WTP-A Required Minimum Residual 0.20 mg/L							
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes		
1	0800	Well #1		0.4			
2	0800	Well #1		0.4			
3	0800	Well #1		0.4			
4	0800	Well #1		0.4	Weekly system inspection		
5	0800	Well #1		0.4			
6	0800	Well #1		0.4			
7	0800	Well #1		0.4			
8	0800	Well #1		0.4			
9	0800	Well #1		0.4			
10	0800	Well #1		0.6			
11	0800	Well #1		0.6	Weekly syst	tem inspection	
12	0800	Well #1		0.6			
13	0800	Well #1		0.6			
14	0800	Well #1		0.6			
15	0800	Well #1		0.6			
16	0800	Well #1		0.6			
17	0800	Well #1		0.6			
18	0800	Well #1		0.6			
19	0800	Well #1		0.6			
20	0800	Well #1		0.6			
21 22	0800 0800	Well #1 Well #1		0.6			
22	0800	Well #1		0.6			
23	0800	Well #1		0.6	Wookly ave	tem inspection/DTW/MTRS	
24	0800	Well #1		0.6			
26	0800	Well #1		0.6			
27	0800	Well #1		0.6			
28	0800	Well #1		0.6			
29	0800	Well #1		0.6			
30	0800	Well #		0.6			
31	0800	Well #		0.6	Weekly syst	tem inspection	
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No							
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours			Did continuous monitoring equipment fail at any time to reporting month? Yes No		ny time this	Date continuous monitoring equipment failed:	
as required? 🗌 Yes 🗌 No			If yes, were grab samples collected every four		r hours until the		
Attach those results and submit them with this form.			continuous monitoring equipment was returne required? Yes No			Date it was returned to service:	
			Attach grab sample results and submit them with		with this form.	1 1	
Printed N	Name: Garrer	n Friedemann	Title	Title: Operations Manager		Operator Certification #:	
Signatur	e:		Phone #: (541) 505-9968		OR		
Date: 11 / 2 / 2021 Small Groundwater System						roundwater Svstem 🖂	

Return by 10th of following month by either email <u>dwp.dmce@state.or.us</u>; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.