## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name McKenzie Ridge Subdivision PWS ID# 4 1 06095						
Month/Year 11 / 2023 Entry Point: WTP-A Required Minimum Residual 0.20 mg/L						
Date	Time	Source(s) ir	1 USE	Lowest free chlorine residual at entry point to distribution system (mg/L)	entry point to Notes	
1	0800	Well #1		0.60	Inspection/Data collection	
2	0800	Well #1		0.60		
3	0800	Well #1		0.60		
4	0800	Well #1		0.60		
5	0800	Well #1		0.60		
6	0800	Well #1		0.60		
7	0800	Well #1		0.60	Inspection/Data collection	
8	0800	Well #1		0.60		
9	0800	Well #1		0.80		
10	0800	Well #1		0.80		
11	0800	Well #1		0.80		
12	0800	Well #1		0.80		
13	0800	Well #1		0.80		
14	0800	Well #1		0.80	Inspection/Data collection	
15	0800	Well #1		0.80		
16	0800	Well #1		0.80		
17	0800	Well #1		0.80		
18	0800	Well #1		0.80		
19	0800	Well #1		0.80		
20	0800	Well #1		0.60	Inspection/E	Data collection/MTR read
21	0800	Well #1		0.60		
22	0800	Well #1		0.60		
23	0800	Well #1		0.60		
24	0800	Well #1		0.60		
25	0800	Well #1		0.60		
26	0800	Well #1		0.60		
27	0800	Well #1		0.60		
28	0800	Well #1		0.60	Inspection/Data collection	
29	0800	Well #1		0.60		
30	0800	Well #		0.60		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? 🔲 Yes 🛛 No						
If yes, what was the longest time period until the required level was restored? hours – <u>If &gt; 4 hours, Drinking Water Program to be</u>						
notified by end of next business day.						
	-	3,300 or Fewer		GWS Serving More Than 3,300		
until the	e residual retu		Did continuous monitoring equipment fail at any reporting month? Yes No		ny time this	Date continuous monitoring equipment failed:
as required? 🗌 Yes 🗌 No			lf yes, were gra	b samples collected every fou	r hours until the	1 1
Attach those results and submit them with this form.			continuous monitoring equipment was returned required?		ed to service as	Date it was returned to service:
				Attach grab sample results and submit them wi		1 1
Printed N	Name: Garrer	n Friedemann	Title: Operations Manager		Operator Certification #: 609860	
Signatur	e:		Phone #: (541) 505-9968		OR	
Date: 12 / 4 / 2023 Small Groundwater System						

Return by 10<sup>th</sup> of following month by either email <u>dwp.dmce@state.or.us</u>; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.