State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	n Name	McKenzie Ridge Subo	livision	PWS ID# 4 1 06095		
Month/Year 3 / 2024 Entry Po			nt: WTP-A	Required Minimum Residual 0.20 mg/L		
Date	Time Source(s) i			Lowest free chlorine residual at entry point to Notes distribution system (mg/L)		
1	0800	Well #		0.40		
2	0800	Well #1		0.40		
3	0800	Well #1		0.40		
4	0800	Well #1		0.40		
5	0800	Well #1		0.40	Inspection/[Data collection
6	0800	Well #1		0.40		
7	0800	Well #1		0.40		
8	0800	Well #1		0.40		
9	0800	Well #1		0.40		
10	0800	Well #1		0.40		
11	0800	Well #1		0.40		
12	0800	Well #1		0.40	Inspection/Data collection	
13	0800	Well #1		0.40		
14	0800	Well #1		0.40		
15	0800	Well #1		0.40		
16	0800	Well #1		0.40		
17	0800	Well #1		0.40		
18	0800	Well #1		0.40		
19	0800	Well #1		0.40	Inspection/[Data collection/MTR read
20	0800	Well #1		0.40		
21	0800	Well #1		0.40		
22	0800	Well #1		0.40		
23	0800	Well #1		0.40		
24	0800	Well #1		0.40		
25	0800	Well #1		0.40		
26	0800	Well #1		0.40		
27	0800	Well #1		0.40		
28	0800	Well #1		0.40		
29	0800	Well #1		0.40	Inspection/[Data collection
30	0800	Well #		0.40		
31	0800	Well #		0.40		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L as required?			· 1			Date continuous monitoring
			reporting mont	h? ☐ Yes ☐ No	,	equipment failed:
Attach those results and submit them with			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as			
this form.			continuous monitoring equipment was returned to service as required? Yes No Service:			
			Attach grab sample results and submit them with this form.			1 1
D. 1 . 1 .		. Edudos				0.045-44- # 400040
Printed Name: Garren Friedemann			Title: Operations Manager		Operator Certification #: 609860	
Signature:			Phone #: (541) 505-9968		OR	
Date: 4	/ 9 / 2024				Small Groundwater System	