

**State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems**

System Name **Birch Creek Golf Course**

PWS ID# **4190240**

Month/Year **02/21** Entry Point: **EP-A for well**

Required Minimum Residual **0.3 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:30	Well UMAT 300/301	1.11	
2	8:25	Well UMAT 300/301	1.12	
3	9:00	Well UMAT 300/301	1.08	
4	10:15	Well UMAT 300/301	1.15	
5	8:45	Well UMAT 300/301	1.09	
6	8:15	Well UMAT 300/301	1.11	
7	9:45	Well UMAT 300/301	1.14	
8	8:29	Well UMAT 300/301	1.01	
9	8:17	Well UMAT 300/301	1.12	
10	9:30	Well UMAT 300/301	1.82	
11	9:18	Well UMAT 300/301	1.92	
12	—	Well UMAT 300/301	—	Closed
13	—	Well UMAT 300/301	—	Closed
14	—	Well UMAT 300/301	—	Closed
15	—	Well UMAT 300/301	—	Closed
16	—	Well UMAT 300/301	—	Closed
17	9:15	Well UMAT 300/301	1.75	Closed
18	12:30	Well UMAT 300/301	1.13	
19	10:40	Well UMAT 300/301	1.13	
20	9:20	Well UMAT 300/301	1.09	
21	8:45	Well UMAT 300/301	1.06	
22	9:10	Well UMAT 300/301	1.02	
23	8:15	Well UMAT 300/301	1.04	
24	7:45	Well UMAT 300/301	1.09	
25	8:15	Well UMAT 300/301	1.11	
26	9:30	Well UMAT 300/301	1.07	
27	8:45	Well UMAT 300/301	1.08	
28	9:15	Well UMAT 300/301	1.11	
29	—	Well UMAT 300/301	—	—
30	—	Well UMAT 300/301	—	—
31	—	Well UMAT 300/301	—	—

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Services to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.3 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No
 Date continuous monitoring equipment failed: / /
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Date it was returned to service: / /
 Attach grab sample results and submit them with this form.

Printed Name: **Chris Stoops**

Title: **Clubhouse Manager**

Signature: *[Handwritten Signature]*

Phone #: **(541) 443-8874**

Date: **3/1/21**

Operator Certification #: n/a

Small Groundwater System