

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name **Birch Creek Golf Course**

PWS ID# **4190240**

Month/Year **Nov / '23** Entry Point: **EP-A for well**

Required Minimum Residual **0.3 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	11:00	Well UMAT 300/301	.63	
2	2:30	Well UMAT 300/301		
3	8:30	Well UMAT 300/301	.46	
4	9:50	Well UMAT 300/301	.53	
5	12:30	Well UMAT 300/301	.38	
6	12:40	Well UMAT 300/301	.36	
7	2:10	Well UMAT 300/301	.47	
8	9:10	Well UMAT 300/301	.53	
9	10:14	Well UMAT 300/301	.42	
10	10:34	Well UMAT 300/301	.46	
11	1:12	Well UMAT 300/301	.44	
12	9:36	Well UMAT 300/301	.50	
13	11:05 AM	Well UMAT 300/301	.49	
14	2:45	Well UMAT 300/301	.39	
15	1:10	Well UMAT 300/301	.32	
16	1:00	Well UMAT 300/301	.38	
17	2:05	Well UMAT 300/301	.75	
18	11:05 AM	Well UMAT 300/301	.54	
19		Well UMAT 300/301		
20		Well UMAT 300/301		
21		Well UMAT 300/301		
22	1:45	Well UMAT 300/301	.34	added chlorine
23	7:20 AM	Well UMAT 300/301	.39	
24	8:35 AM	Well UMAT 300/301	.32	
25	1:15	Well UMAT 300/301	.75	
26	2:20	Well UMAT 300/301	.57	
27	10:00	Well UMAT 300/301	.48	
28		Well UMAT 300/301		
29		Well UMAT 300/301		
30		Well UMAT 300/301		
31		Well UMAT 300/301		

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Services to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.3 mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: **Chris Stoops**

Title: **Clubhouse Manager**

Operator Certification #: **n/a**

Signature: _____

Phone #: **(541) 443-8874**

OR

Date: / /

Small Groundwater System