

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name **Birch Creek Golf Course**

PWS ID# **4190240**

Month/Year **1 / 25** Entry Point: **EP-A for well**

Required Minimum Residual **0.3 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	12:15	Well UMAT 300/301	.82	
2	1357	Well UMAT 300/301	1.69	
3	1115	Well UMAT 300/301	1.82	
4	1330	Well UMAT 300/301	2.5	
5	11:15	Well UMAT 300/301	1.89	
6	11:55	Well UMAT 300/301	1.11	
7	12:09	Well UMAT 300/301	1.06	
8	1008	Well UMAT 300/301	1.60	
9	1215	Well UMAT 300/301	1.30	
10	1000	Well UMAT 300/301	1.80	
11	1040	Well UMAT 300/301	2.10	
12	11:20	Well UMAT 300/301	1.88	
13	12:10	Well UMAT 300/301	1.12	
14	955	Well UMAT 300/301	1.61	
15	8:31	Well UMAT 300/301	.77	
16	1112	Well UMAT 300/301	1.84	
17	1000	Well UMAT 300/301	1.46	
18	11:50	Well UMAT 300/301	.91	
19	11:40	Well UMAT 300/301	.43	
20	12:16	Well UMAT 300/301	1.82	
21	1225	Well UMAT 300/301	1.47	
22	1337	Well UMAT 300/301	1.94	
23	1305	Well UMAT 300/301	1.98	
24	1408	Well UMAT 300/301	1.01	
25	1:18	Well UMAT 300/301	1.08	
26	11:00	Well UMAT 300/301	.82	
27	11:30	Well UMAT 300/301	1.04	
28	1146	Well UMAT 300/301	1.86	
29	3:22	Well UMAT 300/301	1.12	
30	12:08	Well UMAT 300/301	1.89	
31	10:10	Well UMAT 300/301	1.08	

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Services to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.3 mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: **Haylea Fetterhoff**

Title: **Clubhouse manager**

Signature: *HFetterhoff*

Phone #: **(541) 966-1883**

Date: **1 / 31 / 25**

Operator Certification #: **n/a**

Small Groundwater System