

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **Oney's Restaurant/Lounge**

PWS ID# **41 94013**



Month/Year **03 2024** Entry Point: **A - Interim (modified)**

Required Minimum Residual **0.2 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:30am	Oney's Restaurant Sink Faucet	0.4	
2	10am	Restaurant Sink Faucet	0.4	
3	11am	Restroom Sink Faucet	0.3	
4	9:30am	Restroom Sink Faucet	0.3	
5	9:30am	Restroom Sink Faucet	0.2	Added Chlorine to Reservoir
6	9:50am	Restaurant Bathroom Sink Faucet	1.4	
7	9:30am	Restaurant Bathroom Sink Faucet	1.4	
8	9:30am	Restaurant Bathroom Sink Faucet	1.4	
9	9:30am	Restaurant Bathroom Sink Faucet	1.2	
10	9:30am	Restaurant Bathroom Sink Faucet	1.2	
11	9:30am	Restaurant Bathroom Sink Faucet	1.2	
12	11am	Restaurant Bathroom Sink Faucet	1.0	
13	9:30am	Restaurant Bathroom Sink Faucet	0.9	
14	9:30am	Restaurant Bathroom Sink Faucet	0.9	
15	9:30am	Restaurant Bathroom Sink Faucet	0.9	
16	9:30am	Restaurant Bathroom Sink Faucet	0.9	
17	9:30am	Restaurant Bathroom Sink Faucet	0.8	
18	9:30am	Restaurant Bathroom Sink Faucet	0.8	
19	12:00pm	Restaurant Bathroom Sink Faucet	0.6	
20	2:00 pm	Restaurant Bathroom Sink Faucet	0.6	
21	11:30am	Restaurant Bathroom Sink Faucet	0.6	
22	11:30am	Restaurant Bathroom Sink Faucet	0.6	
23	9:30 am	Restaurant Bathroom Sink Faucet	0.6	
24	9:30am	Restaurant Bathroom Sink Faucet	0.6	
25	9:50am	Restaurant Bathroom Sink Faucet	0.5	
26	10 am	Restaurant Bathroom Sink Faucet	0.5	Added more Chlorine
27	9:50am	Restaurant Bathroom Sink Faucet	0.4	
28	9:30am	Restaurant Bathroom Sink Faucet	1.2	
29	9:30am	Restaurant Bathroom Sink Faucet	1.2	
30	9:30am	Restaurant Bathroom Sink Faucet	1.2	
31	9:30am	Restaurant Bathroom Sink Faucet	1.0	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: **Erin Soethe**  
 Signature: *Erin Soethe*  
 Date: **04/07/24**

Title: **Owner Ansed Properties, LLC**  
 Phone #: **(253) 861-3732**

Operator Certification #: \_\_\_\_\_  
 OR  
 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dnce@odhsoha.oregon.gov](mailto:dwp.dnce@odhsoha.oregon.gov); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.