

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Oney's Restaurant/Lounge PWS ID# 4190413  
 Month/Year 03/26 Entry Point: \_\_\_\_\_ Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:30am	Restaurant Restroom Sink Faucet	0.5	
2	9:30am	Restaurant Restroom Sink Faucet	0.5	
3	9:30am	Restaurant Restroom Sink Faucet	0.5	
4	9:30am	"	0.5	
5	9:30am	"	0.4	
6	9:30am	"	0.4	
7	9:30am	"	0.7	Added Chlorine to Reservoir
8	9:30am	"	1.0	
9	9:30am	"	1.0	
10	9:30am	"	1.0	
11	9:30am	"	1.0	
12	9:30am	"	1.0	
13	9:30am	"	1.0	
14	9:30am	"	0.9	
15	9:30am	"	0.9	
16	9:30am	"	0.9	
17	9:30am	"	0.8	
18	9:30am	"	0.8	
19	9:30am	"	0.7	
20	9:30am	"	0.7	
21	9:30am	"	0.7	
22	9:30am	"	0.5	
23	9:30am	"	0.5	
24	9:30am	"	0.5	
25	9:30am	"	0.5	
26	9:30am	"	0.4	
27	9:30am	"	0.4	
28	9:30am	"	0.4	
29	9:30am	"	0.2	Added Chlorine to Reservoir
30	9:20am	Restaurant Restroom Sink Faucet	1.0	
31	9:30am	Restaurant Restroom Sink Faucet	1.0	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: Erin Soethe Title: Owner/Manager Operator Certification #: \_\_\_\_\_  
 Signature: Erin Soethe Phone #: (503) 861-3737 OR  
 Date: 04/09/26 Small Groundwater System