

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year 2/2022

Entry Point: First User (Shop)

Required Minimum Residual .04 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0805	AA,AB,AC,AF	.5	
2	0935	AA,AB,AC,AF	.5	
3	0448	AA,AB,AC,AF	.5	
4	0809	AA,AB,AC,AF	.6	
5	1000	AA,AB,AC,AF	.6	
6	0847	AA,AB,AC,AF	.6	
7	0845	AA,AB,AC,AF	.6	
8	0827	AA,AB,AC,AF	.6	
9	0923	AA,AB,AC,AF	.6	
10	0454	AA,AB,AC,AF	.6	
11	0905	AA,AB,AC,AF	.7	
12	0939	AA,AB,AC,AF	.6	
13	0846	AA,AB,AC,AF	.6	
14	0850	AA,AB,AC,AF	.6	
15	0811	AA,AB,AC,AF	.6	
16	0842	AA,AB,AC,AF	.6	
17	0509	AA,AB,AC,AF	.6	
18	0727	AA,AB,AC,AF	.8	
19	0719	AA,AB,AC,AF	.8	
20	0852	AA,AB,AC,AF	.7	
21	0755	AA,AB,AC,AF	.7	
22	0822	AA,AB,AC,AF	.7	
23	0821	AA,AB,AC,AF	.8	
24	0913	AA,AB,AC,AF	.8	
25	0846	AA,AB,AC,AF	.8	
26	0513	AA,AB,AC,AF	.8	
27	1239	AA,AB,AC,AF	.8	
28	0751	AA,AB,AC,AF	.8	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Steve Croy

Signature: 

Date: 3 / 1 / 2022

Title: Facilities Director

Phone #: (541) 459-1511ext462

Operator Certification #:

OR

Small Groundwater System