

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year 1/2023

Entry Point: First User (Shop)

Required Minimum Residual .04 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1333	AA,AB,AC,AF	.5	
2	1159	AA,AB,AC,AF	.5	
3	1217	AA,AB,AC,AF	.5	
4	0946	AA,AB,AC,AF	.5	
5	0940	AA,AB,AC,AF	.5	
6	1100	AA,AB,AC,AF	.5	
7	0837	AA,AB,AC,AF	.5	
8	1441	AA,AB,AC,AF	.5	
9	1251	AA,AB,AC,AF	.5	
10	0950	AA,AB,AC,AF	.5	
11	0945	AA,AB,AC,AF	.4	
12	1015	AA,AB,AC,AF	.4	
13	1042	AA,AB,AC,AF	.4	
14	1307	AA,AB,AC,AF	.4	
15	0927	AA,AB,AC,AF	.4	
16	1106	AA,AB,AC,AF	.4	
17	1433	AA,AB,AC,AF	.4	
18	1515	AA,AB,AC,AF	.4	
19	0917	AA,AB,AC,AF	.4	
20	1002	AA,AB,AC,AF	.4	
21	1347	AA,AB,AC,AF	.4	
22	1025	AA,AB,AC,AF	.4	
23	1011	AA,AB,AC,AF	.4	
24	1447	AA,AB,AC,AF	.4	
25	1410	AA,AB,AC,AF	.4	
26	0948	AA,AB,AC,AF	.5	
27	0915	AA,AB,AC,AF	.5	
28	1231	AA,AB,AC,AF	.5	
29	1122	AA,AB,AC,AF	.5	
30	1045	AA,AB,AC,AF	.5	
31	0838	AA,AB,AC,AF	.5	

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Steve Croy

Title: Facilities Director

Operator Certification #:

Signature: 

Phone #: (541) 459-1511ext462

OR

Date: 02 / 02 / 2023

Small Groundwater System