

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year 8/2023

Entry Point: First User (Shop)

Required Minimum Residual .04 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0719	AA,AB,AC,AF	.7	
2	0646	AA,AB,AC,AF	.6	
3	0635	AA,AB,AC,AF	.7	
4	0811	AA,AB,AC,AF	1.0	
5	0738	AA,AB,AC,AF	1.0	
6	1949	AA,AB,AC,AF	.9	
7	0845	AA,AB,AC,AF	.8	
8	0721	AA,AB,AC,AF	.5	
9	0723	AA,AB,AC,AF	1.0	
10	0725	AA,AB,AC,AF	.8	
11	0650	AA,AB,AC,AF	.8	
12	0739	AA,AB,AC,AF	1.0	
13	0654	AA,AB,AC,AF	.6	
14	0853	AA,AB,AC,AF	.7	
15	0657	AA,AB,AC,AF	.8	
16	0739	AA,AB,AC,AF	.7	
17	0723	AA,AB,AC,AF	1.0	
18	0750	AA,AB,AC,AF	1.0	
19	0946	AA,AB,AC,AF	1.0	
20	1211	AA,AB,AC,AF	1.0	
21	0622	AA,AB,AC,AF	.6	
22	0829	AA,AB,AC,AF	1.0	
23	0922	AA,AB,AC,AF	1.0	
24	0700	AA,AB,AC,AF	.8	
25	0732	AA,AB,AC,AF	.6	
26	0738	AA,AB,AC,AF	.5	
27	0734	AA,AB,AC,AF	.5	
28	0934	AA,AB,AC,AF	.6	
29	0736	AA,AB,AC,AF	.6	
30	0746	AA,AB,AC,AF	.5	
31	0857	AA,AB,AC,AF	.5	

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 09 / 05 / 2023

Small Groundwater System