

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 01/2024

Entry Point: First User (Shop)

Required Minimum Residual .04 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1334	AA,AB,AC,AF	.5	
2	1037	AA,AB,AC,AF	.5	
3	0837	AA,AB,AC,AF	.5	
4	1125	AA,AB,AC,AF	.5	
5	0741	AA,AB,AC,AF	.6	
6	0615	AA,AB,AC,AF	.6	
7	1342	AA,AB,AC,AF	.6	
8	1100	AA,AB,AC,AF	.5	
9	1101	AA,AB,AC,AF	.6	
10	0958	AA,AB,AC,AF	.5	
11	0909	AA,AB,AC,AF	.6	
12	0913	AA,AB,AC,AF	.6	
13	0628	AA,AB,AC,AF	.5	
14	1402	AA,AB,AC,AF	.5	
15	0830	AA,AB,AC,AF	.5	
16	1127	AA,AB,AC,AF	.5	
17	1005	AA,AB,AC,AF	.5	
18	0821	AA,AB,AC,AF	.4	
19	0747	AA,AB,AC,AF	.4	
20	0925	AA,AB,AC,AF	.4	
21	0916	AA,AB,AC,AF	.4	
22	0933	AA,AB,AC,AF	1.0	
23	1332	AA,AB,AC,AF	.6	
24	0842	AA,AB,AC,AF	.5	
25	1032	AA,AB,AC,AF	.4	
26	1150	AA,AB,AC,AF	.6	
27	1323	AA,AB,AC,AF	.4	
28	0916	AA,AB,AC,AF	.4	
29	0843	AA,AB,AC,AF	.4	
30	0815	AA,AB,AC,AF	.4	
31	1049	AA,AB,AC,AF	.5	

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 02 / 01 / 2024

Small Groundwater System