

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 07/2024

Entry Point: First User (Shop)

Required Minimum Residual .045 mg/

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0734	AA,AB,AC,AF	.6	
2	0712	AA,AB,AC,AF	.6	
3	0625	AA,AB,AC,AF	.6	
4	0634	AA,AB,AC,AF	1.0	
5	0641	AA,AB,AC,AF	.6	
6	0801	AA,AB,AC,AF	.8	
7	0736	AA,AB,AC,AF	.6	
8	0735	AA,AB,AC,AF	1.0	
9	0846	AA,AB,AC,AF	.8	
10	0629	AA,AB,AC,AF	.9	
11	0624	AA,AB,AC,AF	.7	
12	0637	AA,AB,AC,AF	.5	
13	0652	AA,AB,AC,AF	.5	
14	0858	AA,AB,AC,AF	.6	
15	0616	AA,AB,AC,AF	.9	
16	0713	AA,AB,AC,AF	.8	
17	0628	AA,AB,AC,AF	.8	
18	0638	AA,AB,AC,AF	.7	
19	0929	AA,AB,AC,AF	.8	
20	0654	AA,AB,AC,AF	.7	
21	1841	AA,AB,AC,AF	.7	
22	0747	AA,AB,AC,AF	.8	
23	0659	AA,AB,AC,AF	.7	
24	0636	AA,AB,AC,AF	.7	
25	0706	AA,AB,AC,AF	.6	
26	0807	AA,AB,AC,AF	.5	
27	0958	AA,AB,AC,AF	.5	
28	0911	AA,AB,AC,AF	.7	
29	1042	AA,AB,AC,AF	.7	
30	0922	AA,AB,AC,AF	.5	
31	0920	AA,AB,AC,AF	.5	

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 08 / 03 / 2024

Small Groundwater System