

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 09/2024

Entry Point: First User (Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1547	AA,AB,AC,AF	1.0	
2	1040	AA,AB,AC,AF	.8	
3	0731	AA,AB,AC,AF	1.0	
4	0916	AA,AB,AC,AF	.7	
5	0810	AA,AB,AC,AF	.8	
6	0750	AA,AB,AC,AF	.7	
7	0734	AA,AB,AC,AF	1.0	
8	0752	AA,AB,AC,AF	1.0	
9	0858	AA,AB,AC,AF	1.0	
10	0814	AA,AB,AC,AF	1.0	
11	0853	AA,AB,AC,AF	.6	
12	0827	AA,AB,AC,AF	.9	
13	0855	AA,AB,AC,AF	1.0	
14	0814	AA,AB,AC,AF	.7	
15	0908	AA,AB,AC,AF	1.0	
16	0807	AA,AB,AC,AF	1.0	
17	0743	AA,AB,AC,AF	.5	
18	0918	AA,AB,AC,AF	.6	
19	0850	AA,AB,AC,AF	1.0	
20	0835	AA,AB,AC,AF	1.0	
21	1004	AA,AB,AC,AF	1.0	
22	2014	AA,AB,AC,AF	1.0	
23	0840	AA,AB,AC,AF	1.0	
24	0652	AA,AB,AC,AF	1.0	
25	0659	AA,AB,AC,AF	1.0	
26	0712	AA,AB,AC,AF	.6	
27	0840	AA,AB,AC,AF	.6	
28	1114	AA,AB,AC,AF	1.0	
29	1407	AA,AB,AC,AF	1.0	
30	0837	AA,AB,AC,AF	1.0	
31	0000	AA,AB,AC,AF	.NA	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 10 / 03 / 2024

Small Groundwater System