

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year 12/2024

Entry Point: First User (Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1233	AA,AB,AC,AF	.8	
2	2012	AA,AB,AC,AF	.8	
3	0807	AA,AB,AC,AF	.7	
4	1006	AA,AB,AC,AF	.8	
5	1919	AA,AB,AC,AF	.9	
6	0908	AA,AB,AC,AF	.8	
7	2110	AA,AB,AC,AF	.7	
8	1306	AA,AB,AC,AF	.6	
9	1918	AA,AB,AC,AF	1.0	
10	0800	AA,AB,AC,AF	1.0	
11	1205	AA,AB,AC,AF	1.0	
12	1338	AA,AB,AC,AF	.8	
13	0724	AA,AB,AC,AF	.9	
14	0751	AA,AB,AC,AF	.8	
15	1520	AA,AB,AC,AF	1.0	
16	1934	AA,AB,AC,AF	1.0	
17	0753	AA,AB,AC,AF	1.0	
18	1512	AA,AB,AC,AF	1.0	
19	1300	AA,AB,AC,AF	.9	
20	1037	AA,AB,AC,AF	1.0	
21	0819	AA,AB,AC,AF	.8	
22	1705	AA,AB,AC,AF	.8	
23	0929	AA,AB,AC,AF	.9	
24	1834	AA,AB,AC,AF	.6	
25	1626	AA,AB,AC,AF	.7	
26	1904	AA,AB,AC,AF	.7	
27	0927	AA,AB,AC,AF	.8	
28	0713	AA,AB,AC,AF	.5	
29	0746	AA,AB,AC,AF	.7	
30	1413	AA,AB,AC,AF	.7	
31	1315	AA,AB,AC,AF	.6	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 01 / 08 / 2025

Small Groundwater System