

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 01/2025

Entry Point: First User (Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2151	AA,AB,AC,AF	.6	
2	0818	AA,AB,AC,AF	.6	
3	0910	AA,AB,AC,AF	.6	
4	1211	AA,AB,AC,AF	.6	
5	1834	AA,AB,AC,AF	.6	
6	0827	AA,AB,AC,AF	.7	
7	1141	AA,AB,AC,AF	.7	
8	1445	AA,AB,AC,AF	.5	
9	1429	AA,AB,AC,AF	.5	
10	0736	AA,AB,AC,AF	.7	
11	1102	AA,AB,AC,AF	.7	
12	0842	AA,AB,AC,AF	.7	
13	0831	AA,AB,AC,AF	.6	
14	2027	AA,AB,AC,AF	.6	
15	1921	AA,AB,AC,AF	.7	
16	0952	AA,AB,AC,AF	.7	
17	0949	AA,AB,AC,AF	.8	
18	0537	AA,AB,AC,AF	.8	
19	0944	AA,AB,AC,AF	.7	
20	2131	AA,AB,AC,AF	.7	
21	0912	AA,AB,AC,AF	.7	
22	1746	AA,AB,AC,AF	.7	
23	1608	AA,AB,AC,AF	.7	
24	1706	AA,AB,AC,AF	.6	
25	0829	AA,AB,AC,AF	.7	
26	1500	AA,AB,AC,AF	.8	
27	1445	AA,AB,AC,AF	.8	
28	1726	AA,AB,AC,AF	.8	
29	1416	AA,AB,AC,AF	.8	
30	1020	AA,AB,AC,AF	.7	
31	1736	AA,AB,AC,AF	.8	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours – If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Signature: Edward Humber

Phone #: (541) 459-1511ext462

Date: 02 / 05 / 2025

Operator Certification #:

OR

Small Groundwater System ☒

December 19, 2012