

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year \_ 05/2025

Entry Point: First User ( Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0915	AA,AB,AC,AF	.9	
2	2205	AA,AB,AC,AF	.9	
3	0629	AA,AB,AC,AF	.9	
4	1726	AA,AB,AC,AF	.9	
5	1044	AA,AB,AC,AF	.9	
6	0941	AA,AB,AC,AF	.9	
7	1130	AA,AB,AC,AF	.9	
8	1425	AA,AB,AC,AF	.9	
9	0905	AA,AB,AC,AF	.9	
10	1847	AA,AB,AC,AF	.9	
11	0715	AA,AB,AC,AF	.8	
12	1317	AA,AB,AC,AF	.8	
13	1513	AA,AB,AC,AF	.8	
14	1120	AA,AB,AC,AF	.8	
15	0740	AA,AB,AC,AF	.8	
16	0920	AA,AB,AC,AF	.8	
17	1431	AA,AB,AC,AF	.7	
18	1732	AA,AB,AC,AF	.7	
19	0912	AA,AB,AC,AF	.7	
20	1851	AA,AB,AC,AF	.7	
21	1002	AA,AB,AC,AF	.7	
22	1427	AA,AB,AC,AF	.7	
23	1024	AA,AB,AC,AF	.7	
24	1735	AA,AB,AC,AF	.7	
25	1727	AA,AB,AC,AF	.7	
26	1705	AA,AB,AC,AF	.7	
27	1514	AA,AB,AC,AF	.7	
28	1207	AA,AB,AC,AF	.7	
29	1354	AA,AB,AC,AF	.8	
30	1214	AA,AB,AC,AF	.8	
31	1202	AA,AB,AC,AF	.8	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?  
notified by end of next business day.

hours – If > 4 hours, Drinking Water Program to be

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required? ☐ Yes ☐ No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Signature: Edward Humber

Phone #: (541) 459-1511ext462

Date: 06 / 05 / 2025

Operator Certification #:

OR

Small Groundwater System ☒

December 19, 2012