

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year \_ 06/2025

Entry Point: First User ( Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1615	AA,AB,AC,AF	.8	
2	1026	AA,AB,AC,AF	.8	
3	1037	AA,AB,AC,AF	.8	
4	1621	AA,AB,AC,AF	.7	
5	1135	AA,AB,AC,AF	.8	
6	2035	AA,AB,AC,AF	.8	
7	0705	AA,AB,AC,AF	.8	
8	1812	AA,AB,AC,AF	.8	
9	1725	AA,AB,AC,AF	.9	
10	0717	AA,AB,AC,AF	.9	
11	0935	AA,AB,AC,AF	.9	
12	1201	AA,AB,AC,AF	.9	
13	1455	AA,AB,AC,AF	.9	
14	2025	AA,AB,AC,AF	.8	
15	0730	AA,AB,AC,AF	.7	
16	1709	AA,AB,AC,AF	.7	
17	2050	AA,AB,AC,AF	.7	
18	1135	AA,AB,AC,AF	.7	
19	1605	AA,AB,AC,AF	.8	
20	1044	AA,AB,AC,AF	.8	
21	0905	AA,AB,AC,AF	.7	
22	1707	AA,AB,AC,AF	.7	
23	0954	AA,AB,AC,AF	.7	
24	1057	AA,AB,AC,AF	.7	
25	1505	AA,AB,AC,AF	.7	
26	1046	AA,AB,AC,AF	.7	
27	0808	AA,AB,AC,AF	.7	
28	1039	AA,AB,AC,AF	.7	
29	1359	AA,AB,AC,AF	.7	
30	0726	AA,AB,AC,AF	.7	
31	0000	AA,AB,AC,AF	.	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?  
notified by end of next business day.

hours – If > 4 hours, Drinking Water Program to be

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required? ☐ Yes ☐ No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Signature: Edward Humber

Phone #: (541) 459-1511ext462

Date: 07 / 05 / 2025

Operator Certification #:

OR

Small Groundwater System ☒

December 19, 2012