

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 09/2025

Entry Point: First User (Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1010	AA,AB,AC,AF	.7	
2	0858	AA,AB,AC,AF	.8	
3	0923	AA,AB,AC,AF	1.0	
4	1708	AA,AB,AC,AF	1.0	
5	1428	AA,AB,AC,AF	1.0	
6	0934	AA,AB,AC,AF	1.0	
7	1050	AA,AB,AC,AF	1.0	
8	2012	AA,AB,AC,AF	.7	
9	0836	AA,AB,AC,AF	.7	
10	1234	AA,AB,AC,AF	.7	
11	1619	AA,AB,AC,AF	.6	
12	2032	AA,AB,AC,AF	.5	
13	1315	AA,AB,AC,AF	.5	
14	1203	AA,AB,AC,AF	.6	
15	1606	AA,AB,AC,AF	.7	
16	0841	AA,AB,AC,AF	.7	
17	0929	AA,AB,AC,AF	.7	
18	1123	AA,AB,AC,AF	.8	
19	0937	AA,AB,AC,AF	.6	
20	1845	AA,AB,AC,AF	.6	
21	1515	AA,AB,AC,AF	.6	
22	1956	AA,AB,AC,AF	.5	
23	1545	AA,AB,AC,AF	.5	
24	0740	AA,AB,AC,AF	.5	
25	1024	AA,AB,AC,AF	.5	
26	1418	AA,AB,AC,AF	.5	
27	0905	AA,AB,AC,AF	.5	
28	1536	AA,AB,AC,AF	.5	
29	1153	AA,AB,AC,AF	.5	
30	1835	AA,AB,AC,AF	.8	
31		AA,AB,AC,AF	.	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Signature: Edward Humber

Phone #: (541) 459-1511ext462

Date: 10 / 06 / 2025

Operator Certification #:

OR

Small Groundwater System ☒

December 19, 2012