

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Kellogg Springs Camp Christian Camp

PWS ID# 4 1 90490

Month/Year _ 01/2026

Entry Point: First User (Shop)

Required Minimum Residual 0.45 mg

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1111	AA,AB,AC,AF	.5	
2	0830	AA,AB,AC,AF	.5	
3	1025	AA,AB,AC,AF	.6	
4	1413	AA,AB,AC,AF	.6	
5	1803	AA,AB,AC,AF	.6	
6	0905	AA,AB,AC,AF	.5	
7	0924	AA,AB,AC,AF	.6	
8	0801	AA,AB,AC,AF	.5	
9	0714	AA,AB,AC,AF	.5	
10	1015	AA,AB,AC,AF	.5	
11	1232	AA,AB,AC,AF	.5	
12	1716	AA,AB,AC,AF	.6	
13	0731	AA,AB,AC,AF	.7	
14	0944	AA,AB,AC,AF	.7	
15	0832	AA,AB,AC,AF	.7	
16	1238	AA,AB,AC,AF	.7	
17	1030	AA,AB,AC,AF	.6	
18	1141	AA,AB,AC,AF	.5	
19	1413	AA,AB,AC,AF	.6	
20	1618	AA,AB,AC,AF	.5	
21	0940	AA,AB,AC,AF	.7	
22	0914	AA,AB,AC,AF	.7	
23	1250	AA,AB,AC,AF	.6	
24	0942	AA,AB,AC,AF	.6	
25	1128	AA,AB,AC,AF	.5	
26	1202	AA,AB,AC,AF	.7	
27	1016	AA,AB,AC,AF	.5	
28	0914	AA,AB,AC,AF	.5	
29	1022	AA,AB,AC,AF	.5	
30	0852	AA,AB,AC,AF	.6	
31	0932	AA,AB,AC,AF	.7	

Was the chlorine residual ever less than the required minimum residual of .45 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Ed Humber

Title: Facilities Director

Operator Certification #:

Signature: Edward Humber

Phone #: (541) 459-1511ext462

OR

Date: 02 / 09 / 2026

Small Groundwater System