

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name Triangle Lake Charter School PWS ID# 41 90556

Month/Year 11/9/11 21 Entry Point: South Kite Sink Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00		.65	
2	9:00		.60	
3	7:30		.53	
4	8:00		.68	
5				
6		No School		
7				
8	5:10		.55	
9	9:00		.65	
10	10:00		.71	
11	8:00		.69	
12				
13		No School		
14				
15	9:15		.59	
16	9:00		.65	
17	9:00		.70	
18	9:30		.69	
19				
20		No School		
21				
22	9:00		.55	
23	8:30		.60	
24	9:00		.63	
25	9:30		.68	
26				
27		No School		
28				
29	12:00		.69	
30	8:30		.74	
31	9:00		.72	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____/_____/_____                  Date it was returned to service: _____/_____/_____</p>	

Printed Name: Jeff Richardson Title: Transportation Operator Certification #: \_\_\_\_\_  
 Signature: [Signature] Phone #: (591) 925-3262 OR  
 Date: 04/08/2011 E-124 Small Groundwater System