

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Triangle Lake Charter School PWS ID# 41 90556
 Month/Year June 21 Entry Point: South Kite Sink Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00		.60	
2	9:00		.70	
3	8:00		.67	
4	8:00		.73	
5				
6				
7	9:00		.97	
8	8:00		.85	
9	8:30		.80	
10	8:45		.87	
11				
12				
13				
14	8:00		.60	
15	9:00		.65	
16	8:30		.24	
17	9:00		.40	
18				
19				
20				
21	9:00		.65	
22	8:45		.73	
23	8:30		.76	
24	9:30		.83	
25				
26				
27				
28	8:00		.65	
29	9:00		.79	
30	8:30		.75	
31	X		X	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

Date continuous monitoring equipment failed: _____/_____/_____

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Date it was returned to service: _____/_____/_____

Attach grab sample results and submit them with this form.

Printed Name: Jeff Richardson

Title: Transportation

Operator Certification #: _____

Signature: Jeff Richardson

Phone #: 591-925-3262

OR

Date: 7/6/2021

E-124

Small Groundwater System