


**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name		TRIANGLE LAKE CHARTER SCHOOL	PWS ID#	4 1 90566	
Month/Year		06/2023	Entry Point:		SOUTH KITCHEN SINK
			Required Minimum Residual		0.2 mg/L

Date	Time AM	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	5:20		.66	
2	FRI			NO SCHOOL
3	SAT			NO SCHOOL
4	SUN			NO SCHOOL
5	5:30		.68	
6	5:15		.65	
7	5:45		.61	
8	5:45		.59	
9	FRI			NO SCHOOL
10	SAT			NO SCHOOL
11	SUN			NO SCHOOL
12	6:00		.52	
13	5:30		.48	
14	5:00		.51	
15	5:00		.55	
16	FRI			NO SCHOOL
17	SAT			NO SCHOOL
18	SUN			NO SCHOOL
19	MON			JUNETEENTH NO SCHOOL
20	6:00		.60	
21	6:00		.64	
22	5:30		.67	
23	FRI			NO SCHOOL
24	SAT			NO SCHOOL
25	SUN			NO SCHOOL
26	6:00		.65	
27	6:30		.68	
28	6:00		.70	
29	5:45		.69	
30	FRI			NO SCHOOL
31	SAT			NO SCHOOL

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: SHANEZ BENSCOTER	Title: FACILITIES MANAGER	Operator Certification #:
Signature: 	Phone #: (925) 2175	OR
Date: 7 / 3 / 2023		Small Groundwater System <input type="checkbox"/>

Return by 10th of following month by either email dlwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.