State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name							
Month/Year 11/2024 Entry Point: SOUTH KITCHEN SINK Required Minimum Residual 0.2 mg/L							
Date	Time AM	Source(s) ii	ı use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	FRI					NO SCHOO	L
2	SAT					NO SCHOO	L
3	SUN					NO SCHOO	L
4	6:00			.58			
5	6:00			.54			
6	6:00			.55			
7	6:00						
8	FRI					NO SCHOO	L
9	SAT	SAT				NO SCHOOL	
10	SUN					NO SCHOO	
11	6:00			.56		110 001100	
12	5:30			.59			
13	5:30			.60			
14	6:00			.61			
15	FRI					NO SCHOO	I
16	SAT					NO SCHOOL	
17	SUN					NO SCHOO	
18	6:00			.64		110 001100	
19	6:00			.66			
20	5:30			.59			
21	6:00			.55			
22	FRI			.00		NO SCHOO	1
23	SAT				NO SCHOOL		
24	SUN					NO SCHOO	
25	6:00			.56		NO SCHOO	L
26	6:00			.54			
27	WED			.04		NO SCHOO	I DAY OFF
28	THUR					NO SCHOOL DAY OFF THANKSGIVING DAY	
29	FRI		H-1855/195 1955			NO SCHOOL	
30	SAT						
- 50	OAT					NO SCHOO	L
Was the chlorine residual ever less than the required minimum residual of If yes, what was the longest time period until the required level was restored? notified by end of next business day. Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No hours − If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at a reporting month? ☐ Yes ☐ No			ny time this	Date continuous monitoring equipment failed:
as required? Yes No Attach those results and submit them with this form.			If yes, were grab samples collected every four continuous monitoring equipment was returne required?				/ / Date it was returned to service:
arasastri (Carella)			Attach grab sample results and submit them w.			vith this form.	1 1
Printed 1	Name: SHAN	EBENSCOTER	Title: FACILITIES/MAINTENANCE			Operator Certification #:	
Signatur	0		DL			0.5	
							20.00
Date: 12 / 2 / 2024 Small Groundwater System							