

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name TRIANGLE LAKE CHARTER SCHOOL

PWS ID# 41 90566



Month/Year 08/2025

Entry Point: SOUTH KITCHEN SINK

Required Minimum Residual 0.2 mg/L

Date	Time AM	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	FRI			NO SCHOOL
2	SAT			NO SCHOOL
3	SUN			NO SCHOOL
4	6:00		.66	
5	6:00		.64	
6	6:00		.64	
7	6:00		.62	
8	FRI			NO SCHOOL
9	SAT			NO SCHOOL
10	SUN			NO SCHOOL
11	5:30		.59	
12	5:30		.58	
13	6:00		.63	
14	6:00		.62	
15	FRI			NO SCHOOL
16	SAT			NO SCHOOL
17	SUN			NO SCHOOL
18	5:30		.59	
19	5:30		.54	
20	6:00		.55	
21	6:00		.62	
22	FRI			NO SCHOOL
23	SAT			NO SCHOOL
24	SUN			NO SCHOOL
25	6:00		.68	
26	5:30		.62	
27	5:30		.58	
28	6:00		.60	
29	FRI			NO SCHOOL
30	SAT			NO SCHOOL
31	SUN			NO SCHOOL

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours – If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: SHANE BENSCOTER

Title: FACILITIES DIRECTOR

Operator Certification #:

Signature: 

Phone #: (541) 925-3262

OR

Date: 9/4/2025

Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.