State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Rogue Valley Adven	tist Academy	PWS ID# 4 1 90722		
Month/Year 06/2021 Entry Point: EP-A Required Minimum Residual .20 mg/L						
Date	Time	Source(s)	in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
_ 1	8:30 am	AA-Well		.6		
2	7:30 am	AA-Well		.8		
3	7:30 am	AA-Wel		.7		
4	8:00 am	AA-Wel_		.7		
5				offline		
6				offline		
7_	8:00 am	AA-Wel		.7		
8	8:30 am	AA-Well		.7		
9	8:00 am	AA-Well		.7		
10	8:00 am	AA-Wel		.7		
11	7:30 am	AA-Wel		.7		
12				offline		
13	7.00		- .	offline	_	
14	7:30 am	AA-Wel		.7		
15	8:30 am	AA-Well		.7		
16	7:30 am	AA-Well		.8		
17	7:30 am	AA-Wel		.7		
18	8:00 am	AA-Wel		.7		
19				offline		
20	8:00 am	AA-Wel		offline		
22	8:30 am	AA-Well		.7		
23	7:30 am	AA-Well	,	.7		
24	8:00 am	AA-Wel		.7		
25	7:30 am	AA-Wel		.7		
26	7.50 alli	7/1-14CI		offline	_	
27				offline	-	<u> </u>
28	7:30 am	AA-Wel		.7		
29	8:30 am	AA-Well		.7		
30	7:30 am	AA-Well		.7	_	
31	1100 0111	1		1 +1	-	
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored?						
				GWS Serving More Than 3,3		1
If yes, did you monitor every four hours until the residual returned to mg/L? Did continuous reporting month				monitoring equipment fail at any time this n? No		Date continuous monitoring equipment failed:
Attach those results and submit them with If yes, were gi				ab samples collected every four hours until the		1 1
				onitoring equipment was returned to service?		Date it was returned to
				Yes No		service:
Attach grab san				nple results and submit them with this form.		
Printed Name: Mike Glasgow Title: Maintenance Supervisor Operator Certification #:						r Certification #:
Signature/ Phone #: (541) 773-2988 OR						
Date: 07	/07/2021	/.			Small Gr	oundwater System