

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Rogue Valley Adventist Academy**

PWS ID# **4 1 90722**

Month/Year **09/2021** Entry Point: **EP-A**

Required Minimum Residual **.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 am	AA-Well	.7	
2	7:30 am	AA-Well	.7	
3	8:30 am	AA-Well	.7	
4			offline	
5			offline	
6	8:30 am	AA-Well	.7	
7	7:30 am	AA-Well	.7	
8	7:30 am	AA-Well	.7	
9	8:00 am	AA-Well	.7	
10	7:30 am	AA-Well	.7	
11			offline	
12			offline	
13	8:30 am	AA-Well	.7	
14	7:30 am	AA-Well	.7	
15	7:30 am	AA-Well	.7	
16	7:30 am	AA-Well	.7	
17	8:00 am	AA-Well	.7	
18			offline	
19			offline	
20	8:30 am	AA-Well	.7	
21	8:00 am	AA-Well	.7	
22	8:00 am	AA-Well	.7	
23	7:30 am	AA-Well	.8	
24	7:30 am	AA-Well	.8	
25			offline	
26			offline	
27	8:00 am	AA-Well	.7	
28	8:00 am	AA-Well	.7	
29	8:00 am	AA-Well	.7	
30	7:30 am	AA-Well	.7	
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / / Date it was returned to service: / /</p>
--	---	---

Printed Name: **Mike Glasgow**

Title: **Maintenance Supervisor**

Operator Certification #:

Signature: 

Phone #: **(541) 773-2988**

OR

Date: **10 / 04 / 2021**

Small Groundwater System