State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Rogue Valley Advent	ist Academy	PWS ID# 4 1 90722		
Month/Year 10/2021 Entry Point: EP-A Required Minimum Residual .20 mg/L						
Date	Time	Source(s) ii	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	8:00 am	AA-Well		.7		
2				offline		
3				offline		
4	7:30 am	AA-Well	_	.7		
5	8:00 am	AA-Well		.7		
6	8:30 am	AA-Well		.7		
7	7:30 am	AA-Well		.7		
8	7:30 am	AA-Well		.7		
9				offline		
10				offline		
11	7:30 am	AA-Well		.6		
12	8:00 am	AA-Well		.7		
13	8:30 am	AA-Well		.7		
14	7:30 am	AA-Well		.7		
15	7:30 am	AA-Well		.7		
16				offline		
17				offline		
18	8:00 am	AA-Well		.7		
19	7:30 am	AA-Well		.7		
20	8:30 am	AA-Well		.7		
21	8:00 am	AA-Well		.7	<u> </u>	
22	8:00 am	AA-Well		.7		
23				offline		· - · · · · · · · · · · · · · · · · · ·
24				offline		
25	7:30 am	AA-Well		.6		
26	7:30 am	AA-Well		.6		
27	8:00 am	AA-Well		.7		
28	8:00 am	AA-Well		.7		
29	8:00 am	AA-Well		.7		
30				offline		·
31 offline						
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
						l .
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any reporting month? ☐ Yes ☒ No		ny ume uns	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours continuous monitoring equipment was returned to se			/ / Date it was returned to service:
İ			Attach grab sample results and submit them with this		with this form.	
Printed I	Name: Mike	GMS gow/	Title	e: Maintenance Supervisor	Operator Certification #:	
Signature: ///// Phone #: (541) 773-2988 OR						OR
Date: 11 / 04 / 2021 ✓ Small Groundwater System ☐						