State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		Rogue Valley Advent	ist Academy	PW	PWS ID# 4 1 90722		
Month/Year 03/2022 Entry Point: EP-A Required Minimum Residual .20 mg/L							
Date	Time	Source(s) is	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	7:30 am	AA-Well		.7			
2	8:00 am	AA-Well		.7			
3	7:30 am	AA-Well	***	.7			
4	8:00 am	AA-Well		.7			
5				offline			
6	:			offline			
7	8:00 am	AA-Well		.7			
8	8:00 am	AA-Well		.7			
9	7:30 am	AA-Well		.7			
10	7:30 am	AA-Well		.7			
11	8:30 am	AA-Well		.7			
12				offline			
13				offline			
14	8:00 am	AA-Well		.7			
15	8:00 am	AA-Well		.7			
16	7:30 am	AA-Well		.7	İ		
17	7:30 am	AA-Well		.7			
18	8:00 am	AA-Well		.7	İ		
19				offline			
20				offline	İ		
21	7:30 am	AA-Well		.7			
22	7:30 am	AA-Well		.7			
23	8:00 am	AA-Well		.7	ĺ		
24	8:00 am	AA-Well		.7			
25	7:30 am	AA-Well		.7			
26				offline			
27				offline			
28	7:30 am	AA-Well		.7			
29	8:30 am	AA-Well		.6			
30	8:30 am	AA-Well		.6			
31	8:30 am	AA-Well		.6			
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No If yes, what was the longest time period until the required level was restored? hours							
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,3		I	
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time this reporting month? Yes No		iny time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every fou continuous monitoring equipment was returned Yes No		ed to service?	Date it was returned to service:	
			Attach grab sample results and submit them v		with this form.	1 1	
Printed	Name: Mike	Glasgow	Title	e: Maintenance Supervisor	Operator Certification #:		
Signatu	re/////	4 Money	Pho	one #: (541) 773-2988		OR	
Date: 04/08/2022					Small Groundwater System		