State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		Rogue Valley Adventist Academy		PWS ID# 4 1 90722			
Month/Year 04/2022 Entry Point			int: EP-A	Required Minimum Residual .20 mg/L			
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	7:30 am	AA-Well		.7	_	<u></u>	
2			·	offline			
3				offline			
4	8:00 am	AA-Well		.7			
5	8:00 am	AA-Well		.6			
6	7:30 am	AA-Well		.6		<u> </u>	
7	8:00 am	AA-Well		.7			
8	8:00 am	AA-Well		.7			
9				offline			
10				offline			
11	8:30 am	AA-Well		.7			
12	7:30 am	AA-Well		.6			
13	7:30 am	AA-Well		.6			
14	8:00 am	AA-Well		.6			
15	8:00 am	AA-Well		.6			
16				offline			
17	0.00			offline			
18	8:00 am	AA-Well		.6			
_19	8:00 am	AA-Well		.6			
20	8:00 am	AA-Well		.6			
21	7:30 am	AA-Well		.6			
22	7:30 am	AA-Well		.6			
23				offline			
24	7,20	A A 1A/-II		offline			
25 26	7:30 am	AA-Well		.6			
27	7:30 am 8:00 am	AA-Well AA-Well		.6 .6			
28	7:30 am	AA-Well		.6			
29	8:30 am	AA-Well		.6		·	
30	0.50 am	- A-AAGII		offline	-		
31			<u></u>	offline	 		
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No							
If yes, what was the longest time period until the required level was restored?							
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,300			
						Date continuous monitoring equipment failed:	
				grab samples collected every four hours until the monitoring equipment was returned to service? Yes No		/ / Date it was returned to service:	
, Attach grab sar				mple results and submit them with this form.		1 1	
Printed Name; Mike Glasgow Title: Maintenance Supervisor Operator Certification #:						r Certification #:	
Signatur	e:////	4/1/har	Pho	ne #: (541) 773-2988	OR		
Date: 05/04/2022							
טמוט. עני	Date: 05 / 04 / 2022 Small Groundwater System						