## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		Rogue Valley Adventist Academy		PWS ID# 4 1 90722		
Month/Year 06/2022 Entry Point: EP-A Required Minimum Residual .20 mg/L						
Date	Time	Source(s) ii	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	7:30 am	AA-Well		.7		
2	8:00 am	AA-Well		.6		
3	8:00 am	AA-Well		.6		
4				offline		
5				offline		
6	7:30 am	AA-Well		.6		
7	7:30 am	AA-Well		.7		
8	7:30 am	AA-Well		.7		
9	8:00 am	AA-Well		.7		
10	8:00 am	AA-Well		.7		
11				offline		
12	7.00	A A 344-11		offline		
13	7:30 am	AA-Well		.7		
14	7:30 am	AA-Well		.7		
15	7:30 am	AA-Well		.7	-	
16	8:00 am	AA-Well		.7		
17	8:00 am	AA-Well		offline		
18 19			8		-	
20	8:00 am	A A Mall		offline .7		
21	7:30 am	AA-Well AA-Well		.7		
22	7:30 am	AA-Well		.7	P	
23	8:00 am	AA-Well		.7		
24	8:00 am	AA-Well		.7		
25	0.00 am	LV-AACII		offline	+	
26				offline		
27	8:00 am	AA-Well		.7		
28	7:30 am	AA-Well		.7	1	
29	7:30 am	AA-Well		.7		
30	8:00 am	AA-Well		.7		
31	0.00 0	70111011		offline		
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
						I
If yes, did you monitor every four hours Did until the residual returned to mg/L? rep			reporting mont	Did continuous monitoring equipment fail at any time this reporting month?  Yes  No		Date continuous monitoring equipment failed:
				If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Yes No		/ / Date it was returned to service:
Attacl				Attach grab sample results and submit them with this form.		1 1
Printed Name: Mike Dasgow Title: Maintenance Supervisor					Operator Certification #:	
Signature Phone #: (541) 773-2988 OR						
Date: 07 / 05 / 2022 Small Groundwater System						