

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **Rogue Valley Adventist Academy**

PWS ID# **4 1 90722**

Month/Year **10/2022** Entry Point: **EP-A**

Required Minimum Residual **.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:30 am	AA-Well	offline	
2	8:00 am	AA-Well	offline	
3	8:00 am	AA-Well	.7	
4	8:00 am	AA-Well	.7	
5	8:00 am	AA-Well	.7	
6	8:30 am	AA-Well	.7	
7	8:00 am	AA-Well	.7	
8	7:30 am	AA-Well	offline	
9	7:30 am	AA-Well	offline	
10	8:00 am	AA-Well	.7	
11	8:00 am	AA-Well	.7	
12	8:00 am	AA-Well	.7	
13	8:30 am	AA-Well	.7	
14	8:30 am	AA-Well	.7	
15	7:30 am	AA-Well	offline	
16	7:30 am	AA-Well	offline	
17	8:00 am	AA-Well	.7	
18	8:00 am	AA-Well	.7	
19	8:00 am	AA-Well	.7	
20	8:30 am	AA-Well	.7	
21	8:30 am	AA-Well	.7	
22	7:30 am	AA-Well	offline	
23	8:00 am	AA-Well	offline	
24	8:00 am	AA-Well	.7	
25	8:00 am	AA-Well	.7	
26	8:00 am	AA-Well	.7	
27	8:30 am	AA-Well	.7	
28	8:30 am	AA-Well	.7	
29	7:30 am	AA-Well	offline	
30	8:00 am	AA-Well	offline	
31	8:00 am	AA-Well	.7	

Was the chlorine residual ever less than the required minimum residual of **mg/L?** ☐ Yes ☒ No  
If yes, what was the longest time period until the required level was restored? **hours**

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to **mg/L?**  
*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No  
If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
☐ Yes ☐ No  
*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:  
/ /  
Date it was returned to service:  
/ /

Printed Name: **Mike Glasgow**

Signature: 

Date: **11/03/2022**

Title: **Maintenance Supervisor**

Phone #: **(541) 773-2988**

Operator Certification #:

OR

Small Groundwater System ☐