## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		Rogue Valley Adventist Academy		PWS ID# 4 1 90722		
Month/	Year 06/2	2023 Entry Po	int: EP-A	Required Minimum Residual .20 mg/L		
Date	Time	Source(s) ii	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)	24	Notes
1	7:30 am	AA-Well		.7		
2	8:00 am	AA-Well		.7		
3	8:00 am			offline		
4	7:30 am			offline		
5	8:00 am	AA-Well		.7		
6	7:30 am	AA-Well	8/2	.7		
7	8:00 am	AA-Well		.7		
8	7:30 am	AA-Well		.7		
9	7:30 am	AA-Well		.7		
10	8:00 am			offline		
11	7:30 am			offline		1.
12	8:00 am	AA-Well		.7	75	
13	7:30 am	AA-Well		.7	Ì	
14	8:00 am	AA-Well		.7		
15	8:00 am	AA-Well		.7	İ	
16	7:30 am	AA-Well		.7		
17	8:00 am			offline		
18	7:30 am			offline		
19	8:00 am	AA-Well		.7		
20	7:30 am	AA-Well		.7		
21	8:00 am	AA-Well		.7		
22	7:30 am	AA-Well		.7		
23	8:00 am	AA-Well		.7		
24	8:00 am			offline		
25	7:30 am			offline		
26	8:00 am	AA-Well		.7		
27	7:30 am	AA-Well		.7		
28	8:00 am	AA-Well		.7		
29	7:30 am	AA-Well		.7		
30	8:00 am	AA-Well		.7		
31						
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time reporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every for continuous monitoring equipment was returned Yes No		ed to service?	Date it was returned to service:
/			Attach grab sample results and submit them		with this form.	
Printed Name: Mile Clasgow				le: Maintenance Supervisor		r Certification #:
Signature:				ne #: (541) 773-2988	OR	
Date: 0	7/09/2023				Small Groundwater System	