State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Rogue		Rogue Valley Advent	tist Academy	PWS ID# 4 1 90722			
Month/	Year 10/	2023 Entry Po	int: EP-A	Required Minimum Residual .20 mg/L			
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L))	Notes	
1				offline			
2	8:00 am	AA-Well		.7			
3	7:30 am	AA-Well		.7			
4	7:30 am	AA-Well		.7			
5	8:00 am	AA-Well		.7			
6	7:30 am	AA-Well		.7			
7				offline			
8	:			offline			
9	8:00 am	AA-Well		.7			
10	7:30 am	AA-Well		.7			
11	7:30 am	AA-Well		.7			
12	8:00 am	AA-Well		.7			
13	7:30 am	AA-Well		.7			
14				offline			
15				offline			
16	8:00 am	AA-Well		.7		8	
17	7:30 am	AA-Well		.7			
18	7:30 am	AA-Well		.7			
19	8:00 am	AA-Well		.7			
20	7:30 am	AA-Well		.7			
21	7.00 0111	701 11011		offline			
22				offline			
23	7:30 am	AA-Well		.7			
24	7:30 am	AA-Well		.7			
25	7:30 am	AA-Well		.7	10		
26	8:00 am	AA-Well		.7			
27	7:30 am	AA-Well		.7			
28	7.00 0111	70111011		offline			
29				offline			
30	8:00 am	AA-Well		.7			
31	7:30 am	AA-Well		.7			
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No							
I							
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,30		300	
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any tire reporting month? ☐ Yes ☒ No		nny time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four continuous monitoring equipment was returned Yes No			/ / Date it was returned to service:	
			Attach grab sample results and submit them		with this form.	1 1	
Printed Name: Mike Glasgov				e: Maintenance Supervisor Operator Certification #		r Certification #:	
Signature: Phone #: (541) 773					OR		
Date: 1	Date: 11 /04 / 2023 Small Groundwater System						