


**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name	Rogue Valley Adventist Academy	PWS ID#	4 1 90722
Month/Year	01/2024	Entry Point:	EP-A
		Required Minimum Residual	.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 am	AA-Well	.7	
2	8:00 am	AA-Well	.7	
3	7:30 am	AA-Well	.7	
4	8:00 am	AA-Well	.7	
5	7:30 am	AA-Well	.7	
6			offline	
7			offline	
8	8:00 am	AA-Well	.7	
9	8:00 am	AA-Well	.7	
10	7:30 am	AA-Well	.7	
11	8:00 am	AA-Well	.7	
12	7:30 am	AA-Well	.7	
13			offline	
14			offline	
15	8:00 am	AA-Well	.7	
16	8:00 am	AA-Well	.7	
17	7:30 am	AA-Well	.7	
18	8:00 am	AA-Well	.7	
19	7:30 am	AA-Well	.7	
20			offline	
21			offline	
22	8:00 am	AA-Well	.7	
23	7:30 am	AA-Well	.7	
24	7:30 am	AA-Well	.7	
25	8:00 am	AA-Well	.7	
26	7:30 am	AA-Well	.7	
27			offline	
28			offline	
29	8:00 am	AA-Well	.7	
30	8:00 am	AA-Well	.7	
31	8:00 am	AA-Well	.7	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L?  <i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No                  If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  <input type="checkbox"/> Yes <input type="checkbox"/> No  <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:                  / /                  Date it was returned to service:                  / /</p>
--	---	---

Printed Name: Mike Glasgow Signature:  Date: 02 / 02 / 2024	Title: Maintenance Supervisor Phone #: (541) 773-2988	Operator Certification #: OR Small Groundwater System <input type="checkbox"/>
--	--	--