State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Re		Rogue Valley Adventist Academy		PWS ID# 4 1 90722		
Month/	Year 07/	2024 Entry Po	int: EP-A	Required Minimum Residual .20 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	7:30 am	AA-Well		.7		
2	8:00 am	AA-Well		.7		
3	7:30 am	AA-Well		.7		
4	8:00 am	AA-Well		.7		
5	7:30 am	AA-Well		.7		
6				offline		
7				offline		
8	7:30 am	AA-Well		.7		- I
9	8:00 am	AA-Well		.7		
10	7:30 am	AA-Well		.7		
11	8:00 am	AA-Well		.7 _		
12	7:30 am	AA-Well		.7		
13		751115		offline		
14				offline		
15	7:30 am	AA-Well	<u>.</u>	.7		
16	8:00 am	AA-Well		.7		
17	7:30 am	AA-Well		.7	-	
18	8:00 am	AA-Well		.7		
19	7:30 am	AA-Well		.7		
20		75177511		offline		
21				offline		
22	7:30 am	AA-Well		.7		
23	8:00 am	AA-Well		.7		
24	7:30 am	AA-Well		.7	-	
25	8:00 am	AA-Well		.7		
26	7:30 am	AA-Well		.7		
27			200	offline		
28				offline		
29	7:30 am	AA-Well		.7		
30	8:00 am	AA-Well	 -	.7		
31	8:00 am	AA-Well		.7		
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No		Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? Yes No		Date it was returned to service:	
Attach grab sample results and submit them with this form.						
Signatur		Mozen	Title: Maintenance Supervisor Phone #: (541) 773-2988		Operator Certification #: OR	
Date: 08	3/02/2024				Small G	roundwater System