State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		Rogue Valley Adventist Academy		PWS ID# 4 1 90722		
Month/Year 10/2024 Entry Point: EP-A Required Minimum Residual .20 mg/L						
Date	Time	Source(s) ii	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	8:00 am	AA-Well		offline		
2	8:00 am	AA-Well		.7		
3	7:30 am	AA-Well		.7		
4	8:00 am	AA-Well		.7	Ÿ,	
5				offline		
6				offline		
7	8:00 am	AA-Well		.7		
8	7:30 am	AA-Well		.7		
9	8:00 am	AA-Well		.7		
10	7:30 am	AA-Well		.7		
11	8:00 am	AA-Well		.7		7 A - 47779-1970-1-1
12				offline		
13			- No.	offline		
14	8:00 am	AA-Well		.7		
15	7:30 am	AA-Well		.7		
16	8:00 am	AA-Well		.7		
17	7:30 am	AA-Well		.7		
18	8:00 am	AA-Well		.7		
19				offline		
20				offline		
21	8:00 am	AA-Well		.7		
22	7:30 am	AA-Well		.7		
23	8:00 am	AA-Well		.7		SAT SATE OF TWO C
24	7:30 am	AA-Well		.7		
25	8:00 am	AA-Well		.7		
26				offline		
27				offline		
28	8:00 am	AA-Well		.7		
29	7:30 am	AA-Well		.7		
30	8:00 am	AA-Well		.7		
31	7:30 am	AA-Well_		.7		
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
				id continuous monitoring equipment fail at any time this eporting month? Yes No		Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours un continuous monitoring equipment was returned to service. Yes No		ed to service?	Date it was returned to service:
Attach grab sample results and submit them with this form.						
Printed Name: Mike Glasgow Title: Maintenance Supervisor					Operator Certification #:	
Signatur	re: ///	V W/J~C	Pho	one #: (541) 773-2988		OR
Date: 11/04/2024					Small Groundwater System	