


**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name	Rogue Valley Adventist Academy	PWS ID#	4 1 90722
Month/Year	11/2024	Entry Point:	EP-A
		Required Minimum Residual	.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 am	AA-Well	.7	
2			offline	
3			offline	
4	8:00 am	AA-Well	.7	
5	8:00 am	AA-Well	.7	
6	7:30 am	AA-Well	.7	
7	8:00 am	AA-Well	.7	
8	7:30 am	AA-Well	.7	
9			offline	
10			offline	
11	8:00 am	AA-Well	.7	
12	8:00 am	AA-Well	.7	
13	7:30 am	AA-Well	.7	
14	8:00 am	AA-Well	.7	
15	7:30 am	AA-Well	.7	
16			offline	
17			offline	
18	8:00 am	AA-Well	.7	
19	8:00 am	AA-Well	.7	
20	7:30 am	AA-Well	.7	
21	8:00 am	AA-Well	.7	
22	7:30 am	AA-Well	.7	
23			offline	
24			offline	
25	8:00 am	AA-Well	.7	
26	8:00 am	AA-Well	.7	
27	7:30 am	AA-Well	.7	
28	8:00 am	AA-Well	.7	
29	7:30 am	AA-Well	.7	
30			offline	
31			offline	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L?  <i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No                  If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  <input type="checkbox"/> Yes <input type="checkbox"/> No  <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:                  / /                  Date it was returned to service:                  / /</p>
--	---	---

Printed Name: Mike Glasgow Signature:  Date: 12/04/2024	Title: Maintenance Supervisor Phone #: (541) 773-2988	Operator Certification #: OR Small Groundwater System <input type="checkbox"/>
--	--	--