State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Rogue Valley Adventist Academy PWS ID# 4 1 90722						90722	
Month/Year 04/2025 Entry Point: EP-A Required Minimum Residual .20 mg/L							
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L	I	Notes	
1	8:00 am	AA-Weil		.7			
2	7:30 am	AA-Well		.7			
3	8:00 am	AA-Well		.7			
4	8:00 am	AA-Well		.7			
5				offline			
6	0.00	A A 3 A L 3 L		offline			
7	8:00 am	AA-Weil		.7			
8	7:30 am	AA-Well		.7			
9	8:00 am	AA-Well		.7			
10	7:30 am 8:00 am	AA-Well AA-Well		.7	_		
12	0.00 am	AA-VVEII		offline			
13				offline	-		
14	8:00 am	AA-Well		.7			
15	8:00 am	AA-Well		.7			
16	7:30 am	AA-Well		.7			
17	7:30 am	AA-Well		.7			
18	8:00 am	AA-Well		.7			
19	0.00 0.11	70111011		offline			
20				offline			
21	8:00 am	AA-Well		.7			
22	7:30 am	AA-Well		.7			
23	8:00 am	AA-Well		.7			
24	7:30 am	AA-Well		.7			
25	8:00 am	AA-Well		.7			
26				offline			
_ 27				offline			
28	8:00 am	AA-Well		.7			
29	8:00 am	AA-Well		.7			
30	7:30 am	AA-Well		.7			
31				offline			
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No If yes, what was the longest time period until the required level was restored? hours							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours Did continuous				monitoring equipment fail at any time this n? Yes No		Date continuous monitoring equipment failed:	
				ab samples collected every four hours until the		1 1	
				tinuous monitoring equipment was returned to service?		Date it was returned to service:	
			Attach grab sar	mple results and submit them with this form.		1 1	
Printed Name: Mike Massall Day Title: Maintenance Supervisor Operator Certification #:							
Signature	e: V / /	rvioge	Pho	ne #: (541) 773-2988	OR		
Date: 04	Date: 04 / 02 / 2025 Small Groundwater System						