

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name **Humbug Mtn SP**

PWS ID# **4 1 91018**

Month/Year **07/22** Entry Point: **WTP-A**

Required Minimum Residual **0.3 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10 A		.55	shop SH
2	8:30 A		.70	shop SH
3	8:00 A		.58	shop gw
4	8:00 A		.61	shop gw
5	8:20 A		.57	shop SH
6	8:10 A		.67	shop SH
7	8:25 A		.49	shop SH
8	8:10 A		.51	shop SH
9	8:15 A		.46	shop SH
10	8:00 A		.47	shop gw
11	8:00 A		.52	shop gw
12	8:20 A		.44	shop SH
13	8:15 A		.51	shop SH
14	8:40 A		.45	shop RC
15	8:45 A		.44	shop RC
16	8:30 A		.52	shop RC
17	8:25 A		.51	shop RC
18	11:00 A		.52	shop gw
19	8:00 A		.59	shop gw
20	8:45 A		.53	shop SH
21	8:20 A		.55	shop SH
22	8:30 A		.52	shop SH
23	8:50 A		.51	shop SH
24	8:25 A		.46	shop RC
25	8:00 A		.60	shop gw
26	8:15 A		.46	shop SH
27	8:20 A		.51	shop SH
28	8:20 A		.49	shop SH
29	8:10 A		.59	shop SH
30	8:20 A		.51	shop SH
31	8:00 A		.60	shop gw

Was the chlorine residual ever less than the required minimum residual of **0.3 mg/L**?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: **Steve Husted**

Title: **PR2**

Operator Certification #: \_\_\_\_\_

Signature: *Steve Husted*

Phone #: **(541) 332-6724**

OR

Date: **08/02/2022**

Small Groundwater System